



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Purba Medinipur**  
**West Bengal Fire & Emergency Services**  
**Dharinda, P.O.-: Tamluk, Purba Medinipur, Pin:- 721636**

Memo no.: WBFES/HOW/700/15

Date: 03-03-2021

**From:**

**Divisional Fire Officer, Purba Medinipur**  
**West Bengal Fire & Emergency Services**

**To: DHYANESWAR SUBODH COLLEGE**

**VILL-GOGRAS COURT TALUK PO-RAGHUNATHBARI PS-PANSKURA DIST-PURBA MEDINIPUR PIN-721634**

**Sub: Renewal of Fire Safety Certificate for the occupancy of G+II storied Building in the name & style of " DHYANESWAR SUBODH COLLEGE" under group of Educational Building at Vill-Gogras, P.O.- Raghunathbari, P.S- Panskura, Dist.- Purba Medinipur.**

This is in reference to your application no. 0125191211400015 dated 07-02-2021 regarding the Renewal of Fire Safety Certificate for the occupancy of G+II storied Building in the name & style of " DHYANESWAR SUBODH COLLEGE" under group of Educational Building at Vill-Gogras, P.O.- Raghunathbari, P.S- Panskura, Dist.- Purba Medinipur.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. All the Fire Safety Recommendation which was issued by this office vide memo no.- WBFES/DY.DFS(WZ)FP-903/13. dt:- 13/11/13 to be followed strictly at all times.
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
3. Underground reservoir capacity shall have to be increased upto 30000 ltrs.
4. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
5. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
6. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them,

particularly lines above false ceiling and ducts.

7.A Fire Control Room including a CCTV system will have to be maintained, which observe all floors of the building.

8.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.

9.The employees and security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire and Testing.

10.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.

11.Transformer and switch gear room shall be protected with automatic CO2 or D.C.P. Fire Extinguishers confirming I.S. specification.

12.Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

13.Unauthorized cooking arrangement in any floor of the building using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.

14.A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.

15.First-Aid Fire Fighting system shall be provided as per I.S. specification.

16.Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.

17.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

18.Existing lift shall be treated as fire lift in case of emergency.

19.Periodical flashing of water from the Hydrant and Sprinkler pipe lines shall be made to maintain the efficient working performance of above mentioned system.

20.The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.

21.The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.

22.No addition & alternation without prior permission of West Bengal Fire & Emergency Services, otherwise Fire Safety certificate will be treated as cancelled.

This Fire Safety Certificate is valid for three year and has to be renewed after three year as per Govt. Notification No: 629\_L. Dt.-17.04.18.

Signature valid

Digitally signed by SUNIL  
KUMAR MANDAL  
Date: 2021.03.03 15:59:54 IST

Divisional Fire Officer, Purba Medinipur  
West Bengal Fire & Emergency Services